



EN TEST EVIDENCE FOR STREBORD DOOR CORES

STREBORD 44				BS EN 1634-1														
Test Ref	Chilt/RF11121			Chilt/RF11170			Chilt/RF13132			Chilt/RF13176			Chilt/RF13263 Doorset A			Chilt/RF13263 Doorset B		
Product Tested	Equal Pair 2055 x 927			Equal Pair 2135 x 915			Equal Pair 2150 x 928			Single Leaf 2148 x 928			Single Leaf 2155 x 955			Single Leaf 2155 x 955		
Category	E	I ₁	I ₂	E	I ₁	I ₂	E	I ₁	I ₂	E	I ₁	I ₂	E	I ₁	I ₂	E	I ₁	I ₂
Result	38	N/A	19	38	N/A	38	36	36	36	32	32	32	41	38	41	32	32	32

Strebord 44 EXAP - [BMT/CNA/F14053](#)

Maximum Permitted Door Leaf Sizes						
LSASD/ ULSASD	2322 x 1047	2410 x 1033	2365 x 1020	2318 x 928	2542 x 1126	2219 x 983
LSADD/ ULSADD*	2322 x 1047	2410 x 1033	2365 x 1020	-	-	-
*Unequal Leaf Min	2322 x 463	2410 x 457	2365 x 464	-	-	-

STREBORD 54				BS EN 1634-1					
Test Ref	Chilt/RF11143			Chilt/RF11171			Chilt/RF12068		
Product Tested	Equal Pair - 2054 x 928			Equal Pair - 2135 x 915			Single Door - 2442 x 917		
Category	E	I ₁	I ₂	E	I ₁	I ₂	E	I ₁	I ₂
Result	61	N/A	61	60	N/A	60	66	N/A	66

Strebord 54 EXAP - [BMT/CNA/F14054 Rev A](#)

Maximum Permitted Door Leaf Sizes			
LSASD/ ULSASD	2442 x 935	2135 x 915	2442 x 935
LSADD/ ULSADD*	2071 x 935	2135 x 915	-
*Unequal Leaf Min	2071 x 464	2135 x 457	-

Contact us for more information



Gateshead Depot
Haydock Depot
High Wycombe Depot
Leeds Depot
Nottingham Depot
Tilbury Depot
West Bromwich Depot

T 0191 338 8208
T 01744 416 600
T 01494 291 777
T 0113 887 2222
T 0115 919 2000
T 01375 487 300
T 0121 525 8844

E gateshead@falconnpp.co.uk
E haydock@falconnpp.co.uk
E highwycombe@falconnpp.co.uk
E leeds@falconnpp.co.uk
E nottingham@falconnpp.co.uk
E tilbury@falconnpp.co.uk
E westbrom@falconnpp.co.uk

Falcon Panel Products Ltd
Clock House
Station Approach
Shepperton, Middlesex
TW17 8AN
E sales@falconnpp.co.uk
www.falconnpp.co.uk

