

## Certificate of Registration

**Certificate Number 020**

Placed on the Market under the Name of

**Falcon Timber Ltd  
The Enterprise Building  
Ferry Road, Port of Tilbury  
Tilbury  
Essex  
RM18 7HL  
United Kingdom**

and produced in the manufacturing plants

**Factory F1 (E001508): Details held on file  
Factory F3 (E001626): Details held on file  
Factory F5 (E004232): Details held on file  
Factory F12 (E002315): Details held on file  
Factory F12A (E003383): Details held on file  
Factory F14 (E001308): Details held on file  
Factory F19 (E004209): Details held on file**


This certificate attests that all provisions have been met concerning the BM TRADA requirements of the scheme:

**Q-Mark Timber Fire Door Manufacture**

Date of Initial Certification: **27/01/2009**

Date of Last Issue: **31/07/2024**

Date of Expiry: **08/02/2026**



**Jon Lessimore (Divisional Director)**  
For and on behalf of Element

## Scope of Certification

### Primary Field of Application (FoA) Reports (owned by this certified company)

Either used in isolation, or can be used in conjunction with an appropriate associated document for this company, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely

| Type                                                         | FoA Report      | Rev | Owned by Certified Company named on this scope | Doorset Description                                                                                                                                    | Integrity Period | FoA Standard |
|--------------------------------------------------------------|-----------------|-----|------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|--------------|
| <b>Blanks Manufactured at Factory 3 (STREbord® 35)</b>       |                 |     |                                                |                                                                                                                                                        |                  |              |
| Fire                                                         | Chilt/A12137    | A   | Falcon Timber Limited                          | STREbord® 35 doorsets for 30 Minutes Fire Resistance (Glazed or Unglazed)                                                                              | 30min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| Fire                                                         | WF380559        | A   | Falcon Timber Limited                          | STREbord® 35+ doorsets for 30 Minutes Fire Resistance (Glazed or Unglazed)                                                                             | 30min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| <b>Blanks Manufactured at Factory 1, 3, 5 (STREbord® 44)</b> |                 |     |                                                |                                                                                                                                                        |                  |              |
| Fire                                                         | Chilt/A02066    | O   | Falcon Timber Limited                          | STREbord® 44 door assemblies for 30 Minutes Fire Resistance (Glazed or Unglazed)                                                                       | 30min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| <b>Blanks Manufactured at Factory 3 (STREbord® 44 AV)</b>    |                 |     |                                                |                                                                                                                                                        |                  |              |
| Fire                                                         | WF407090        | B   | Falcon Timber Limited                          | STREbord® 44 doorsets for 30 Minutes Fire Resistance (Front Entrance Doorsets) (Glazed or Unglazed)                                                    | 30min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| Fire                                                         | WF417523        | -   | Falcon Timber Limited                          | STREbord® 44+ doorsets for 60 Minutes Fire Resistance (Unglazed only)                                                                                  | 60min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| <b>Blanks Manufactured at Factory 3 (STREbord® 54 AV)</b>    |                 |     |                                                |                                                                                                                                                        |                  |              |
| Fire                                                         | Chilt/A02067    | K   | Falcon Timber Limited                          | STREbord® 54 doorsets for 60 Minutes Fire Resistance (Glazed or Unglazed)                                                                              | 60min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| Fire                                                         | Chilt/A02066    | O   | Falcon Timber Limited                          | STREbord® 54 door assemblies for 30 Minutes Fire Resistance (Glazed or Unglazed)                                                                       | 30min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| Fire                                                         | WF407090        | B   | Falcon Timber Limited                          | STREbord® 54 doorsets for 30 Minutes Fire Resistance (Front Entrance Doorsets) (Glazed or Unglazed)                                                    | 30min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| Fire                                                         | WF427764        | -   | Falcon Timber Limited                          | STREbord® 54 Fire Resisting Doorsets for 60 minutes fire resistance (Front Entrance Doorsets) (Glazed or Unglazed)                                     | 60min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| Fire                                                         | Chilt/A10152    | D   | Falcon Timber Limited                          | STREbord® 54 Panelled Range of Doorsets using STREbord® 54 Panelled Door Blanks in Timber Based Door Frames 60 Minutes Fire Resistance (Unglazed only) | 60min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| <b>Blanks Manufactured at Factory 14 (STREdor® 44)</b>       |                 |     |                                                |                                                                                                                                                        |                  |              |
| Fire                                                         | BMT/CNA/ F15159 | F   | Falcon Timber Limited                          | STREdor® 44 doorsets for 30 Minutes Fire Resistance (Glazed or Unglazed)                                                                               | 30min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| Fire                                                         | WF407090        | B   | Falcon Timber Limited                          | STREdor® 44 doorsets for 30 Minutes Fire Resistance (Front Entrance Doorsets) (Glazed or Unglazed)                                                     | 30min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| <b>Blanks Manufactured at Factory 14 (STREdor® 54)</b>       |                 |     |                                                |                                                                                                                                                        |                  |              |
| Fire                                                         | WF407090        | B   | Falcon Timber Limited                          | STREdor® 54 doorsets for 30 Minutes Fire Resistance (Front Entrance Doorsets) (Glazed or Unglazed)                                                     | 30min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| Fire                                                         | WF377027        | A   | Falcon Timber Limited                          | STREdor® 54 Doorsets for 30 Minutes Fire Resistance (Glazed or Unglazed)                                                                               | 30min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| Fire                                                         | WF377027        | A   | Falcon Timber Limited                          | STREdor® 54 Doorsets for 60 Minutes Fire Resistance (Glazed or Unglazed)                                                                               | 60min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| Fire                                                         | WF427764        | -   | Falcon Timber Limited                          | STREdor® 54 Fire Resisting Doorsets for 60 minutes fire resistance (Front Entrance Doorsets) (Glazed or Unglazed)                                      | 60min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| <b>Material in kit form manufactured at Factory 8 (WSCP)</b> |                 |     |                                                |                                                                                                                                                        |                  |              |
| Fire                                                         | Chilt/A12138    | A   | Falcon Timber Limited                          | Warm Springs Composite Products 60 Minutes Fire Resisting Doorsets (Glazed or Unglazed)                                                                | 60min            | BS 476 Pt22  |
| Smoke                                                        | N/A             | -   | -                                              |                                                                                                                                                        |                  | N/A          |
| Fire                                                         | Chilt/A12138    | A   | Falcon Timber Limited                          | Warm Springs Composite Products 90                                                                                                                     | 90min            | BS 476 Pt22  |

|                                                         |              |   |                       |                                                                                                                                        |        |             |
|---------------------------------------------------------|--------------|---|-----------------------|----------------------------------------------------------------------------------------------------------------------------------------|--------|-------------|
| Smoke                                                   | N/A          | - | -                     | Minutes Fire Resisting Doorsets (Glazed or Unglazed)                                                                                   |        | N/A         |
| Fire                                                    | Chilt/A12138 | A | Falcon Timber Limited | Warm Springs Composite Products 120 Minutes Fire Resisting Doorsets (Glazed or Unglazed)                                               | 120min | BS 476 Pt22 |
| Smoke                                                   | N/A          | - | -                     |                                                                                                                                        |        | N/A         |
| <b>Blanks Manufactured at Factory 12/12A (Duocore®)</b> |              |   |                       |                                                                                                                                        |        |             |
| Fire                                                    | Chilt/A12296 | B | Falcon Timber Limited | Duocore Range of Doorsets Using 44mm thick Door Blanks in Timber Based Door Frames for 30 Minutes Fire Resistance (Glazed or Unglazed) | 30min  | BS 476 Pt22 |
| Smoke                                                   | N/A          | - | -                     |                                                                                                                                        |        | N/A         |
| <b>Blanks Manufactured at Factory F19 (Ramkor)</b>      |              |   |                       |                                                                                                                                        |        |             |
| Fire                                                    | WF383876     | B | Falcon Timber Limited | The Ramkor Range of Doorsets Using Particleboard Door blanks in Timber based Door Frames (Glazed or Unglazed)                          | 90min  | BS 476 Pt22 |
| Smoke                                                   | N/A          | - | -                     |                                                                                                                                        |        | N/A         |

**Primary Extended Field of Applications (EXAP)**

| Type                                                         | Exap Report    | Rev | Owned by Certified Company named on this scope | Doorset Description                                                                                                              | Integrity Period | EXAP Standard |
|--------------------------------------------------------------|----------------|-----|------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------|------------------|---------------|
| <b>Blanks Manufactured at Factory 1, 3, 5 (STREbord® 44)</b> |                |     |                                                |                                                                                                                                  |                  |               |
| Fire                                                         | BMT/CNA/F14053 | A   | Falcon Timber Limited                          | STREbord® 44 EI30, 30 Minutes (Integrity and insulation) Fire Resisting Doorsets (EXAP) (Glazed or Unglazed)                     | 30min            | EN 1634-1     |
| Smoke                                                        | N/A            | -   | -                                              |                                                                                                                                  |                  | N/A           |
| <b>Blanks Manufactured at Factory 3 (STREbord® 54)</b>       |                |     |                                                |                                                                                                                                  |                  |               |
| Fire                                                         | BMT/CNA/F14054 | A   | Falcon Timber Limited                          | STREbord® 54, 60 Minutes Fire Resisting Doorsets (EXAP) (Glazed or Unglazed)                                                     | 60min            | EN 1634-1     |
| Smoke                                                        | N/A            | -   | -                                              |                                                                                                                                  |                  | N/A           |
| <b>Blanks Manufactured at Factory 14 (STREdor® 44)</b>       |                |     |                                                |                                                                                                                                  |                  |               |
| Fire                                                         | WF428387       | -   | Falcon Timber Limited                          | STREdor® 44 E30 FED, 30 Minute (Integrity) Fire Resisting and Smoke Control Doorsets (EXAP) (Glazed or Unglazed)                 | 30min            | EN 1634-1     |
| Smoke                                                        | WF428364       | -   | Falcon Timber Limited                          |                                                                                                                                  |                  | EN 1634-3     |
| Fire                                                         | WF428388       | -   | Falcon Timber Limited                          | STREdor® 44 EI30 FED, 30 Minute (Integrity and insulation) Fire Resisting and Smoke Control Doorsets (EXAP) (Glazed or Unglazed) | 30min            | EN 1634-1     |
| Smoke                                                        | WF428364       | -   | Falcon Timber Limited                          |                                                                                                                                  |                  | EN 1634-3     |

**Primary Field of Application (FoA) Reports (owned by and cascaded by a System Supplier)**

The revision status of each FoA can be verified on the BM TRADA website under each System Supplier's certification entry. They are either used in isolation, or can be used in conjunction with an appropriate associated document for this company, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

| Type  | FoA Report | System Supplier owner of Assessment Report | Doorset Description | Integrity Period | FoA Standard |
|-------|------------|--------------------------------------------|---------------------|------------------|--------------|
| Fire  | -          | -                                          | -                   | -                | -            |
| Smoke | -          | -                                          | -                   | -                | -            |

**Test Reports**

Test reports cannot be used in conjunction with any primary FoA reports, other test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

| Type      | Test Report | Owner of Test Report | Doorset Description | Integrity Period | Test Standard |
|-----------|-------------|----------------------|---------------------|------------------|---------------|
| Fire only | -           | -                    | -                   | -                | -             |