

CONSTRUCTIONAL SPECIFICATION FOR CERTIFIRE APPROVED CF 808

Introduction

This document specifies constructional and other details for FD60 doors manufactured from 54mm thick Strebord timber door blanks and certified by CERTIFIRE under certificate No. CF808. Only doors complying with the details of this document may be marked or marketed as CERTIFIRE approved. Any change to, or deviation from, this specification requires the agreement of CERTIFIRE.

General

CERTIFIRE approval is applicable to both complete door assemblies and door leaves. Where the door is not supplied in a fully fitted form it is a condition of approval that an agreed Data Sheet accompanies the product and is complied with in its entirety. Failure to do so will render the approval invalid and may jeopardise the fire performance of the product.

Scope of Approval

As defined in Certificate of Approval No. CF808.

1. <u>Leaf and Overpanel Construction</u>		
1.1 Core:	Material:	STREbord 54 fine surface wood particleboard
	Thickness:	54 mm minimum
	Density:	570 - 650 kg/m ³
1.2 Internal Framing:	Not required	
1.3 Constructional facing:	Not required	
1.4 Decorative finishes:	See Data Sheet	
1.5 Lippings:	See Data Sheet STRElip is a laminated hardwood material of minimum density 720kg/m ³ .	
1.6 Moisture content:	The moisture content of all timber based components shall be 9% (±2%).	

An additional 5 mm thick MDF face may be applied to the STREbord blank, to give an overall leaf thickness of 64 mm (excluding decorative faces).

2. <u>Leaf Dimensions</u>		
2.1 Leaf thickness:	54 mm + 10 mm / - 1 mm (excluding decorative finish)	
2.2 Leaf height / width:	As specified in Certificate of Approval	
2.3 Configuration:	As specified in Certificate of Approval	
2.4 Meeting edges:	Square only (rebated meeting stiles are not permitted)	

3. Door Frame

As specified in Data Sheet

4. Overpanels / Sidepanels

As specified in Data Sheet

5. Glazed Fanlights

- 5.1 Any CERTIFIRE approved glazing system may be used providing the installation details given in the appropriate certification documents are adhered to.

6. Glazed Apertures

- 6.1 One or more glazed openings systems may be included in each leaf.

6.2 Apertures As specified in Data Sheet

6.3 Glazing system: As specified in Data Sheet

6.4 Lining to aperture: As required by the CERTIFIRE glazing certificate

7. Hardware/Intumescent Seals

As specified in Data Sheet

8. Labels

- 7.1 Labels of the CERTIFIRE design referencing CERTIFIRE CF808 and FD60 fire resistance, to be applied to each approved door leaf in the prescribed position